

NRC Inspection Closeout Summary

Date: 9/1/2009

Inspection #: **2009-003** Inspection Period **8/31/09 thru 9/4/09**

Inspection Focus:

Resident Quarterly

Special Focus: **Fire Protection**

Inspector Finding(s)¹:

Concise Description

1 potential violation for failure to identify IROFS affected by work activities

1 URI for disabling sole IROFS system without compensatory measures in place

¹ Information provided at inspection closeouts is not final, and is subject to modification by the NRC prior to issuance of the Inspection Report. To determine the final disposition of a finding, refer to the Inspection Report by the inspection number given above. Inspection Reports follow closeouts by about 2 to 4 weeks. Information recorded for NFSFacts.com is believed to be accurate at the time of recording by the NFS Licensing Department.